

CITY OF CAPE TOWN QUARTERLY DRINKING WATER QUALITY REPORT. ANALYTICAL DATA AND APPROXIMATE DISTRIBUTION FOR CAPE TOWN DRINKING WATER. Sample period: 01 April 2026 to 30 June 2026.

When our residents open their taps, they can trust their water is reliable, tested, treated and safe to drink. The City of Cape Town is legally required to publish tap water quality analytical data once a year, to demonstrate continued compliance with water quality standards, or inform residents of possible risks. City of Cape Town tap water has for many years maintained ‘excellent’ compliance status with prescribed national drinking water quality standards (SANS 241:2015). The quarterly tap water quality reports are available on the City’s website (www.capetown.gov.za/waterquality). Regular monthly updates are also available on the National Department of Water and Sanitation’s ‘My Water’ page for water quality (<http://ws.dwa.gov.za/IRIS/mywater.aspx>). This ‘excellent’ quality City water costs only 6–8.5c a litre compared to about R15 a litre for shop-bought bottled water. See the water quality results below provided across Cape Town for the 01 April 2026 to 30 June 2026 period.

PARAMETERS	SANS 241:2015 Specifications	BLACKHEATH SUPPLY Max 430 Mℓ/day	FAURE SUPPLY Max 500 Mℓ/day	KLOOF NEK SUPPLY Max 22.5 Mℓ/day	STEENBRAS SUPPLY Max 150 Mℓ/day	VOËLVLEI SUPPLY Max 273 Mℓ/day	WEMMERSHOEK SUPPLY Max 250 Mℓ/day	BROOKLANDS SUPPLY Max 5.5 Mℓ/day	HELDERBERG SUPPLY Max 12 Mℓ/day	WITZANDS SUPPLY Max 15 Mℓ/day	CONSTANTIA NEK SUPPLY Max 3 Mℓ/day	ALBION SPRING SUPPLY Max 2 Mℓ/day
PHYSICAL & AESTHETIC DETERMINANDS												
Colour mg/ℓ Pt-Co	≤ 15	6	6	6	6	5	6	6	5	5	–	5
Conductivity mS/m	≤ 170	10	13	15	12	14	9	38	17	19	–	22
Total Dissolved Solids mg/ℓ	≤ 1200	67	89	101	81	92	62	258	111	126	–	146
Turbidity NTU	Operational ≤ 1 / Aesthetic ≤ 5	0.7	0.5	0.5	0.5	0.6	1.0	0.5	0.6	0.5	–	1.0
pH	≥ 5 to ≤ 9.7	8.2	8.5	8.2	8.1	8.7	8.0	8.4	9.1	7.7	–	7.0
CHEMICAL – MACRO DETERMINANDS												
Free chlorine as Cl ₂ mg/ℓ	≤ 5	1.2	1.1	1.0	1.1	1.1	1.3	1.0	1.1	1.1	–	0.7
Nitrate as N mg/ℓ	≤ 11	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.4	–	1.6
Nitrite as N mg/ℓ	≤ 0.9	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	–	< 0.1
Combined nitrate plus nitrite	≤ 1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	–	0.2
Sulphate as SO ₄ ²⁻ mg/ℓ	Aesthetic ≤ 250 / Acute health ≤ 500	17	29	30	16	14	18	60	5	22	–	10.2
Fluoride as F ⁻ mg/ℓ	≤ 1.5	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	–	0.1
Ammonia as N mg/ℓ	≤ 1.5	< 0.4	< 0.4	–	< 0.4	< 0.4	< 0.4	< 0.4	< 0.4	< 0.4	–	< 0.4
Chloride as Cl ⁻ mg/ℓ	≤ 300	12	15	22	21	21	11	70	31	31	–	48
Sodium as Na mg/ℓ	≤ 200	5	8	13	12	11	4	55	13	19	–	26
Zinc as Zn mg/ℓ	≤ 5	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	–	< 0.1
CHEMICAL – MICRO DETERMINANDS												
Antimony as Sb µg/ℓ	≤ 20	11	11	20	9	8	12	9	9	10	–	8
Arsenic as As µg/ℓ	≤ 10	6	6	10	5	4	6	5	5	5	–	4
Barium as Ba µg/ℓ	≤ 700	< 50	< 50	< 50	< 50	< 50	< 50	< 50	< 50	< 50	–	< 50
Boron as B mg/ℓ	≤ 2.4	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	–	< 0.1
Cadmium as Cd µg/ℓ	≤ 3	< 3	< 3	< 3	< 3	< 3	< 3	< 3	< 3	< 3	–	< 3
Chromium (Total) as Cr µg/ℓ	≤ 50	13	13	20	12	10	13	12	12	12	–	11
Copper as Cu µg/ℓ	≤ 2000	17	16	21	17	37	17	16	17	23	–	19
Cyanide as CN ⁻ µg/ℓ	≤ 200	< 10	< 10	–	< 10	< 10	< 10	< 10	< 10	< 10	–	< 10
Iron as Fe µg/ℓ	Chronic Health ≤ 2000 / Aesthetic ≤ 300	53	166	< 50	< 50	53	55	71	51	< 50	–	< 50
Lead as Pb µg/ℓ	≤ 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10	–	< 10
Manganese as Mn µg/ℓ	Chronic Health ≤ 400 / Aesthetic ≤ 100	15	14	20	17	10	21	27	12	12	–	13
Mercury as Hg µg/ℓ	≤ 6	< 5	< 5	< 5	< 5	< 5	< 5	< 5	< 5	< 5	–	< 5
Nickel as Ni µg/ℓ	≤ 70	13	13	20	12	11	13	12	12	12	–	11
Selenium as Se µg/ℓ	≤ 40	6	6	10	5	4	6	5	5	5	–	4
Uranium as U µg/ℓ	≤ 30	< 15	< 15	< 15	< 15	< 15	< 15	< 15	< 15	12	–	12
Aluminium as Al µg/ℓ	≤ 300	160	52	411	211	55	163	69	54	53	–	54
CHEMICAL – ORGANIC DETERMINANDS												
Total Organic Carbon mg/ℓ	≤ 10	2	2	2	2	2	2	4	2	3	–	1
Phenols µg/ℓ	≤ 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10	–	< 10
Chloroform µg/L	≤ 300	2	6	36	10	20	20	8	11	49	–	1
Bromoform µg/L	≤ 100	1	1	1	3	6	2	4	4	9	–	2
Dibromochloromethane µg/L	≤ 100	1	1	< 1	6	4	2	6	9	8	–	< 1
Bromodichloromethane µg/L	≤ 60	1	3	4	6	5	4	5	9	11	–	< 1
Combined Trihalomethane	≤ 1	0.1	0.1	0.2	0.3	0.2	0.1	0.2	0.4	0.5	–	< 0.1
MICROBIOLOGICAL DETERMINANDS												
<i>E. coli</i> count/100mℓ	Not detected	ND	ND	ND	ND	ND	ND	ND	ND	ND	–	ND
Heterotrophic Plate Count count/mℓ	≤ 1000	5	1	1	1	29	4	2	8	3	–	31
Total coliforms count/100mℓ	≤ 10	1	1	1	1	1	1	1	1	1	–	2
OTHER												
Hardness (Total) as CaCO ₃ mg/ℓ	–	27	46	33	22	37	15	42	44	43	–	37
Alkalinity as CaCO ₃ mg/ℓ	–	10	10	8	8	18	9	10	28	19	–	13
Calcium as Ca mg/ℓ	–	9	14	10	6	10	8	9	14	12	–	5
Potassium as K mg/ℓ	–	0.8	0.9	1.0	0.8	1.0	1.3	1.3	1.2	1.8	–	1.0
Magnesium as Mg mg/ℓ	–	1.2	1.7	1.4	1.4	2.5	1.0	4.4	2.5	2.5	–	6.0

KEY: ND = Not detected
– = No specification or no data

The water treatment plants supply water into an interconnected system of reservoirs and pipelines serving the municipal area.

Cosntantia Nek WTP did not produce water during this period.

LUNGELO MBANDAZAYO

CITY MANAGER

